



ਦਫਤਰ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ
ਨੰ: 1 ਫਰੀਦਕੋਟ, ਜ਼ਿਲਾ ਫਰੀਦਕੋਟ - 151203
email. sdesub1@gmail.com

ਵੱਲ

RISHI MODEL SCHOOL,
DHILWAN ROAD, PANJGRAIN KALAN,
FARIDKOT.


ਪੱਤਰ ਨੰ: 111

ਮਿਤੀ: 11/02/25

ਵਿਸ਼ਾ:- ਵਾਟਰ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਬਾਰੇ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਸਬੰਧੀ ਆਪ ਵੱਲੋਂ ਇਸ ਦਫਤਰ ਨੂੰ ਉਕਤ ਸਕੂਲ ਦਾ ਵਾਟਰ ਸੈਂਪਲ ਜਮ੍ਹਾਂ ਕਰਵਾਇਆ ਗਿਆ (ਰਿਪੋਰਟ ਨਾਲ ਨੱਥੀ ਹੈ) ਜੋ ਕਿ ਸਾਫ ਸੁਥਰਾ ਅਤੇ ਪੀਣ ਯੋਗ ਪਾਇਆ ਗਿਆ ਹੈ। ਇਸ ਤੋਂ ਇਲਾਵਾ ਆਪ ਦੇ ਸਕੂਲ ਦਾ ਸੈਨੀਟੇਸ਼ਨ ਵੀ ਚੈਕ ਕੀਤਾ ਗਿਆ ਜੋ ਕਿ ਸਾਫ ਸੁਥਰਾ ਅਤੇ ਵਧੀਆ ਪਾਇਆ ਗਿਆ। ਉਕਤ ਦੇ ਆਧਾਰ ਤੇ ਆਪ ਨੂੰ ਇਹ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ।

ਨੱਥੀ/ਵਾਟਰ ਟੈਸਟਿੰਗ ਰਿਪੋਰਟ ਦੀ ਕਾਪੀ


ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,
ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ ਨੰ:1,
ਫਰੀਦਕੋਟ।

DISTRICT WATER TESTING LABORATORY, FARIDKOT
Department of water supply and sanitation, Ghanaiya Chowk, Opposite Khalsa sr. sec. school, Faridkot
dwtlfdk@gmail.com

RISHI MODEL SCHOOL ,DHILWAN ROAD ,PANJGRAIN KALAN ,FARIDKOT
RISHI MODEL SCHOOL ,DHILWAN ROAD ,PANJGRAIN KALAN ,FARIDKOT


No.: DWTL/FDK/2425/00322 Dated : 11/02/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. R M S/002 Dated: 15/01/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 15/01/2025. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Faridkot

D/A : Test Report



Authorized Signatory
For, District water Testing Laboratory
Faridkot



TC-13893

TEST REPORT

Name & Address of Customer : RISHI MODEL SCHOOL ,DHILWAN ROAD PANJGRAIN KALAN ,FARIDKOT RISHI MODEL SCHOOL ,DHILWAN ROAD PANJGRAIN KALAN ,FARIDKOT		Customer Reference No.	No : R M S/002 Dated : 15/01/2025	
		Sample Submitted by	JATENDER SINGH	
		Date of Sample Receipt	15/01/2025	
		Analysis Starting Date	20/01/2025	
		Analysis completion Date	21/01/2025	
Discipline : Chemical Testing		Group: Water		
ULR No.:	TC10394250000084F	Sample Type :	Treated Water	
Test Report No.:	DWTL/FDK/2425/00322	Date of Issue :	11/02/2025	
Registration no.:	DWTL/FDK/REG2425/00815	Condition of Sample :	Sealed	
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles	
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	RISHI MODEL SCHOOL ,DHILWAN ROAD PANJGRAIN KALAN ,FARIDKOT / NA	
Village :	Not Mentioned	Habitation :	Not Mentioned	
Block:	Faridkot	District :	Faridkot	
Latitude :	Not Mentioned	Longitude:	Not Mentioned	

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.10	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	160	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	52	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	92	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	22.4	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	8.74	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	58	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Manju Vans

Mrs. Manju
Quality Manager
Authorized Signatory
For, District water Testing Laboratory
Faridkot

----- End of the Test Report -----