

DISTRICT WATER TESTING LABORATORY, BATHINDA

Water Supply & Sanitation Division no. 3 Complex, Head Water works, Bhagu Road Bathinda
dwtlbathinda@gmail.com



TEST REPORT

Name & Address of Customer : President Jai Tulsi Anuvrat School Mehraj		Customer Reference No.	No : JTA/25/312 Dated : 17/07/2025
		Sample Submitted by	Sh.Hardeepinder Singh
		Date of Sample Receipt	17/07/2025
		Analysis Starting Date	18/07/2025
		Analysis completion Date	21/07/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC12834250000393F	Sample Type :	Water
Test Report No.:	DWTL/BTI/2526/00200	Date of Issue :	21/07/2025
Registration no.:	DWTL/BTI/REG2526/01004	Condition of Sample :	Unsealed
Collection Point:	NA	Quantity/Type of Bottle:	1000 ml / NA
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Water Sample from Jai Tulsi Anuvrat School ; Mehraj / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Rampura	District :	Bathinda
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.82	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	BDL	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	88	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	36	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	72	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	19.2	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	5.8	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	15.9	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition:

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

(Signature)

Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Bathinda

----- End of the Test Report -----

DISTRICT WATER TESTING LABORATORY, BATHINDA

Water Supply & Sanitation Division no. 3 Complex, Head Water works, Bhagu Road Bathinda
dwtlbathinda@gmail.com

To,

President
Jai Tulsi Anuvrat School Mehraj

No.: DWTL/BTI/2526/00200 Dated : 21/07/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. JTA/25/312 Dated: 17/07/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 17/07/2025. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Bathinda

D/A : Test Report



**Authorized Signatory
For, District Water Testing Laboratory
Bathinda**



ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ
ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ, ਫੂਲ ਐਟ ਬਠਿੰਡਾ
ਨਜ਼ਦੀਕ ਗੁਰੂਦੁਆਰਾ ਸਾਹਿਬ ਮਾਡਲ ਟਾਊਨ, ਭਾਗੂ ਰੋਡ, ਬਠਿੰਡਾ
Email:-sdewssphul@gmail.com



No. 625

Date: 29/07/2025

CERTIFICATE

The Jai Tulsi Anuvrat School, Rampura-Mehraj Road, Mehraj was visited by Shri Hardev Singh, JE (DWSS) to check the public health amenities in your premises on dated 28.07.2025. As per his Physical verification report, the premises were found to be hygienically neat and clean. It is certified that the institution provides safe drinking water facilities for students and staff, as per attached water sample test report by the District Water Testing Lab, Bhagu Road, Bathinda's letter no DWLT/BTI/2526/00200 dated 21.07.2025. Additionally, the academy maintains hygienic sanitation conditions in the school building and campus in accordance with the norms prescribed by the Central/State/U.T. Government.

This certificate is valid up to 31.03.2026.

Sub Divisional Engineer
W/S & Sanitation Sub Div
Phul at Bathinda

Subject:-



ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ, ਫੂਲ ਅਟ ਬਾਠੰਡਾ
ਨਜ਼ਦੀਕ ਗੁਰਦੁਆਰਾ ਸਾਹਿਬ ਮਾਡਲ ਟਾਊਨ, ਭਾਗੂ ਰੋਡ, ਬਠਿੰਡਾ
Email:-sdewssphul@gmail.com



To:-

President

the school

Jai Tulsi Anuvrat School (CBSE Pattern)

well known

Rampura-Mehraj Road, Mehraj

Distt- Bathinda

the letter

Letter No: 625

Date: 29/07/25

Subject-

Certificate for Water & Sanitation for the Year 2025-26.

Reference -

Your Letter No JTA/25/319 Dated: 24.07.2025

In reference to the subject mentioned above, and based on the attached water sample test report, it is hereby certified that the institution is maintaining proper hygiene and sanitation standards. This certificate is issued on the condition that the institution will comply with the Government of Punjab Rules regarding the proper arrangement of safe drinking water, as well as hygiene and sanitation practices.

The Area JE/In-charge assigned by this office will conduct periodic inspections of the site. Any negligence observed will result in the imposition of a penalty. Additionally, please note that failure to comply with the above conditions will lead to the cancellation of the permission granted.

Note- You are hereby instructed to ensure that drinking water samples from your institution are chemically tested every two months from District Water Testing Laboratory, Bathinda. A copy of each test report must be submitted to this office promptly. Non-compliance with this directive may lead to the cancellation of your certificate.

40
Sub Divisional Engineer
WS & Sanitation Sub Div
Phul at Bathinda