

ਦੱਲ

Saraswati Genius School,  
Jaitu  
ਨੰ: DB/3219

ਮਿਤੀ: 14/07/25

ਵਿਸ਼ਾ:-

ਸਾਲ 2025-26 ਲਈ ਸਕੂਲ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਬਾਰੇ। (Saraswati Genius School, Jaitu)

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਅਧੀਨ ਸਕੂਲ ਦੀ ਇਮਾਰਤ ਦਾ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਸਾਲ 2025-26 ਲਈ ਆਪ ਵੱਲੋਂ ਇਸ ਦਫਤਰ ਵਿਖੇ ਪ੍ਰਾਪਤ ਹੋਇਆ ਹੈ। ਆਪ ਦੇ ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਦਾ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ ਦੇ ਦਫਤਰ ਵੱਲੋਂ ਵਿਜ਼ੁਅਲੀ ਇੰਸਪੈਕਸ਼ਨ ਕੀਤੀ ਗਈ ਅਤੇ ਉਨ੍ਹਾਂ ਦੀ ਰਿਪੋਰਟ/ਸਿਫਾਰਿਸ਼ ਅਨੁਸਾਰ ਨਿਮਨਲਿਖਤ ਨਿਰੀਖਣਾਂ ਅਤੇ ਸ਼ਰਤਾਂ ਅਧੀਨ ਸਾਲ 2025-26 ਦਾ ਸਕੂਲ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਮਿਤੀ 31-03-2026 ਜਾਂ ਫਿਰ ਫਾਇਰ ਸੇਫਟੀ ਦੀ ਮਿਆਦ 17.08.2025 (ਦੋਨਾਂ ਵਿੱਚੋਂ ਪਹਿਲਾਂ ਆਉਣ ਵਾਲੀ ਮਿਤੀ ਤੱਕ) ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ:-

1. ਸਕੂਲ ਕੋਲ ਕਿਸੇ ਅਣਸੁਖਾਵੀਂ ਆਪਦਾ ਨਾਲ ਨਜਿੱਠਣ ਲਈ ਯੋਜਨਾ ਹੋਣੀ ਚਾਹੀਦੀ ਹੈ, ਜਿਸ ਵਿੱਚ ਐਮਰਜੈਂਸੀ ਦੌਰਾਨ ਬੱਚਿਆਂ ਨੂੰ ਬਿਲਡਿੰਗ ਵਿੱਚੋਂ ਸੁਰੱਖਿਅਤ ਬਾਹਰ ਕੱਢਣਾ ਅਤੇ ਸਬੰਧਤ ਵਿਭਾਗ ਨਾਲ ਤਾਲਮੇਲ ਕਰਨ ਦੀ ਯੋਜਨਾ ਹੋਣੀ ਚਾਹੀਦੀ ਹੈ। ਸਕੂਲ ਨੂੰ ਇਸ ਯੋਜਨਾ ਦੀ ਪ੍ਰਭਾਵਸ਼ੀਲਤਾ ਨੂੰ ਯਕੀਨੀ ਬਣਾਉਣ ਲਈ ਨਿਯਮਿਤ ਤੌਰ ਤੇ ਸਮੀਖਿਆ ਅਤੇ ਅਪਡੇਟ ਕਰਦੇ ਰਹਿਣਾ ਚਾਹੀਦਾ ਹੈ।
2. ਜੇਕਰ ਸਕੂਲ ਵੱਲੋਂ ਇਸ ਇਮਾਰਤ ਵਿੱਚ ਕੋਈ ਵਾਧਾ, ਤਬਦੀਲੀ, ਵਿਸਤਾਰ ਅਤੇ ਸੋਧ ਦੀ ਲੋੜ ਹੈ ਜਾਂ ਕੀਤੇ ਜਾਣੇ ਹਨ ਤਾਂ ਇਸ ਦਫਤਰ ਨੂੰ ਤਰਤੀਬ ਜਾਂਚ ਦਾ ਪ੍ਰਬੰਧ ਕੀਤੀ ਜਾਣਾ ਚਾਹੀਦਾ ਹੈ ਅਤੇ ਉਸ ਹਿੱਸੇ ਨੂੰ ਮੁਕੰਮਲ ਕਰਕੇ ਉਸਦਾ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਇਸ ਦਫਤਰ ਪਾਸੇ ਫਿਰ ਤੋਂ ਲਿਆ ਜਾਵੇ।
3. ਜੇਕਰ ਬਿਲਡਿੰਗ ਦੀਆਂ ਕੰਧਾਂ, ਨੀਹਾਂ ਅਤੇ ਛੱਤਾਂ ਕੁਦਰਤੀ ਆਫ਼ਤ ਜਾਂ ਕਿਸੇ ਹੋਰ ਕਾਰਨ ਕਰਕੇ ਬੈਠ ਜਾਣ ਤਾਂ ਇਸ ਸੂਰਤ ਵਿੱਚ ਸਕੂਲ ਵੱਲੋਂ ਇਸ ਦਫਤਰ ਨੂੰ ਤੁਰੰਤ ਬਿਲਡਿੰਗ ਦੀ ਹਾਲਤ ਬਾਰੇ ਸੂਚਿਤ ਕੀਤਾ ਜਾਵੇ ਅਤੇ ਨਿਰੀਖਣ ਕਰਵਾਉਣ ਉਪਰੰਤ ਹੀ ਬਿਲਡਿੰਗ ਨੂੰ ਵਰਤੋਂ ਵਿੱਚ ਲਿਆ ਜਾਵੇ।
4. ਸਬੰਧਤ ਵਿਭਾਗ ਤੋਂ ਵੱਖਰੇ ਤੌਰ ਤੇ ਫਾਇਰ ਸੇਫਟੀ ਅਤੇ ਇਲੈਕਟ੍ਰੀਕਲ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਪ੍ਰਾਪਤ ਕੀਤਾ ਜਾਵੇ।
5. ਸਕੂਲ ਬਿਲਡਿੰਗ ਦੀ ਸੇਫਟੀ ਨੂੰ ਮੁੱਖ ਰੱਖਦੇ ਹੋਏ ਬਿਲਡਿੰਗ ਦੀ ਰਿਪੋਅਰ ਕਰਵਾਉਣ ਦੀ ਜ਼ਿੰਮੇਵਾਰੀ ਸਕੂਲ ਪ੍ਰਬੰਧਨ ਦੀ ਹੈ। ਇਸ ਰਿਪੋਰਟ ਦੇ ਬਾਵਜੂਦ ਸਕੂਲ ਪ੍ਰਬੰਧਨ ਸਾਰੇ ਪੱਖਾਂ ਤੋਂ ਬਿਲਡਿੰਗ ਦੀ ਸੁਰੱਖਿਆ ਲਈ ਜ਼ਿੰਮੇਵਾਰ ਹੈ।
6. ਨਿਰਮਾਣ ਆਰਕੀਟੈਕਟਸ (Innovus Structural Engineers and Consultants) ਵੱਲੋਂ ਮਿਤੀ 11.07.2025 ਨੂੰ ਸਟਰੱਕਚਰ ਸੁਰੱਖਿਆ ਸਰਟੀਫਿਕੇਟ ਦਿੱਤਾ ਗਿਆ ਹੈ ਅਤੇ ਉਹਨਾਂ ਦੇ ਸਰਟੀਫਿਕੇਟ ਅਨੁਸਾਰ ਸਕੂਲ ਸੈਸ਼ਨ 2025-26 ਲਈ ਵਰਤੋਂ ਲਈ ਸੁਰੱਖਿਅਤ ਹੈ, ਪਰੰਤੂ ਇਸ ਸਕੂਲ ਦਾ ਨਿਰਮਾਣ ਇਸ ਵਿਭਾਗ ਵੱਲੋਂ ਨਹੀਂ ਕੀਤਾ ਗਿਆ ਹੈ, ਇਸ ਲਈ ਇਸ ਵਿਭਾਗ ਦੁਆਰਾ ਸਕੂਲ ਦੀ ਸਟਰੱਕਚਰ ਸੇਫਟੀ ਖਾਸ ਕਰਕੇ ਭੂਚਾਲ ਦੇ ਦ੍ਰਿਸ਼ਟੀਕੋਣ ਤੋਂ ਯਕੀਨੀ ਨਹੀਂ ਬਣਾਈ ਜਾ ਸਕਦੀ ਹੈ।
7. ਸਕੂਲ ਨੂੰ ਸਟਾਫ ਸੈਬਰਾਂ ਨੂੰ ਉਚਿਤ ਸੁਰੱਖਿਆ ਸਿਖਲਾਈ ਪ੍ਰਦਾਨ ਕਰਨੀ ਚਾਹੀਦੀ ਹੈ, ਜਿਸ ਵਿੱਚ ਐਮਰਜੈਂਸੀ, ਫਸਟ ਏਡ ਅਤੇ ਨਿਕਾਸੀ ਪ੍ਰੋਟੋਕੋਲ ਨੂੰ ਸੰਭਾਲਣ ਦੀਆਂ ਪ੍ਰਕਿਰਿਆਵਾਂ ਵੀ ਸ਼ਾਮਲ ਹਨ।
8. ਸਕੂਲ ਦੇ ਕਵਰਡ ਏਰੀਏ ਦੇ ਹਿਸਾਬ ਨਾਲ ਜੀ.ਆਰ. ਨੰਬਰ 17248554 ਮਿਤੀ 28.04.2025 ਰਾਹੀਂ ਦਸ ਹਜ਼ਾਰ ਰੁਪਏ (10,000/-) ਬਿਲਡਿੰਗ ਨਿਰੀਖਣ ਫੀਸ ਵੱਜੋਂ ਪ੍ਰਾਪਤ ਕੀਤੇ। ਸਕੂਲ ਦਾ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ 17.08.2025 ਤੱਕ ਵੈਲਿਡ ਹੈ ਅਤੇ ਸਕੂਲ ਪ੍ਰਬੰਧਨ ਸਮੇਂ ਸੀਮਾ ਅੰਦਰ ਫਾਇਰ ਸਰਟੀਫਿਕੇਟ ਰੀਨਿਊ ਕਰਵਾਉਣ ਲਈ ਜ਼ਿੰਮੇਵਾਰ ਹੋਵੇਗਾ। ਜੇਕਰ ਸਕੂਲ ਪ੍ਰਬੰਧਨ ਵੱਲੋਂ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਰਿਨਿਊ ਨਹੀਂ ਕਰਵਾਇਆ ਜਾਂਦਾ ਤਾਂ ਇਸ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਦੀ ਮਿਆਦ 17.08.2025 ਤੱਕ ਹੋਵੇਗੀ।
9. ਇਸ ਪੱਤਰ/ਸਰਟੀਫਿਕੇਟ ਦਾ ਸਕੂਲ ਦੀ ਜਗ੍ਹਾ ਦੀ ਮਲਕੀਅਤ ਨਾਲ ਕੋਈ ਸਬੰਧ ਨਹੀਂ ਹੈ।
10. ਇਸ ਪੱਤਰ/ਸਰਟੀਫਿਕੇਟ ਦਾ ਸਕੂਲ ਦੇ ਪਲਾਟ ਏਰੀਏ ਦਾ ਕੋਈ ਸਬੰਧ ਨਹੀਂ ਹੈ।
11. ਇਸ ਮਨਜ਼ੂਰੀ ਦਾ ਸ਼ਡਿਊਲਡ ਰੋਡ ਐਕਟ ਨਾਲ ਕੋਈ ਸਬੰਧ ਨਹੀਂ ਹੈ।
12. ਇਹ ਰਿਪੋਰਟ ਕਾਨੂੰਨੀ ਉਦੇਸ਼ ਲਈ ਵੈਲਿਡ ਨਹੀਂ ਹੈ।

ਨੱਥੀ/ ਸਰਟੀਫਿਕੇਟ

ਪਿੱਠ ਅੰਕਣ ਨੰ:

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,  
ਪ੍ਰਾਂਤਕ ਮੰਡਲ ਭਤੇਮ ਸ਼ਾਖਾ,  
ਫਰੀਦਕੋਟ।  
ਮਿਤੀ:

ਉਪਰੋਕਤ ਦਾ ਉਤਾਰਾ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਉਸਾਰੀ ਉਪ ਮੰਡਲ, ਭ ਤੇ ਮ ਸ਼ਾਖਾ, ਜੈਤੋ ਨੂੰ ਉਨ੍ਹਾਂ ਦੇ ਪੱਤਰ ਨੰਬਰ 38 ਮਿਤੀ 22.04.2025 ਦੇ ਹਵਾਲੇ ਵਿੱਚ ਸੂਚਨਾ ਹਿਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ।

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,  
ਪ੍ਰਾਂਤਕ ਮੰਡਲ ਭਤੇਮ ਸ਼ਾਖਾ,  
ਫਰੀਦਕੋਟ।

# Proforma for Safety of School Building

Part-I

(To be filled by the head of School/Institute)

- 1 Name of the School: Saraswati Genius School
- 2 Location: Bathinda road, Jaitu
- 3 Plot Area: 102600 Sq. ft.
- 4 Plinth Area: 25970 Sq. ft. + 15161 Sq. ft. + 317 Sq. ft.  $\Rightarrow$  41448 Sq. ft.
- 5 Number of Storeys: 02
- 6 Year of Construction of Building: 2000, 2001, 2004
- 7 If the building has been constructed under the supervision of the qualified Engineer the following  
a) Name of the Engineer with qualification: SC Et.  
b) Address of Engineer: MJ Architects  
c) Set of Structural drawings used in the construction if available: Self  
d) Name & Address of the Architect with qualification: Self
- 8 Whether the building has been constructed for the purpose of: Self  
a) School ☒ Yes/No ☒  
b) Residential purpose and converted for use as a school ☒ Yes/No ☒
- 9 Material used for roofs  
a) R.C.C. Slabs/R.B.C. Slabs ☒ Yes/No ☒  
b) R.S. Joists & Battons ☒ Yes/No ☒  
c) Wooden Joists & Battons ☒ Yes/No ☒
- 10 Material used for walls  
a) Mud Mortar ☒ Yes/No ☒  
b) Cement Mortar ☒ Yes/No ☒  
c) Lime Mortar ☒ Yes/No ☒
- 11 Flooring  
a) Conglomerate ☒ Yes/No ☒  
b) Terrazo ☒ Yes/No ☒  
c) Brick Paving ☒ Yes/No ☒
- 12 A detailed drawing indicating dimensions of the rooms, alongwith size and location of doors and window (Attached) ☒ Yes/No ☒
- 13 FOR FIRE SAFETY:  
a) Whether the width of the staircase is 1.5 mtr. ☒ Yes/No ☒  
b) Whether Portable fire extinguisher exists ☒ Yes/No ☒  
c) Whether School building is free from inflammable & toxic material ☒ Yes/No ☒  
d) Whether cooking of food is done at a safe place ☒ Yes/No ☒  
e) Whether any thatch or combustible material has been used ☒ Yes/No ☒  
14 Requirement for Fire Protection arrangements under NBC Part IV (For building height less than 15 metre)  
a) Whether hose reel provided ☒ Yes/No ☒  
b) Whether down comer provided ☒ Yes/No ☒  
c) Whether underground static water storage tank of capacity 50000 Ltr. (if converted are excess 1500 sq.m.) ☒ Yes/No ☒



Fire Safety Certificate Attached

Principal  
Saraswati Genius School  
Jaitu

Dikaneh



d) Whether over head tank of capacity 10000 Ltrs. Exists  
(In case of hose reel 20000 Ltr.)

Yes/No

e) Whether one electric and one diesel pump of 3 Kg/Cum  
pressure of capacity 1620 LPM. One electric pump of  
capacity 180 LPM exist near underground static tank.

Yes/No

f) Whether a pump 3 Kg/Cum pressure & 450/500 LPM  
exists near over head tank.

Yes/No

Principal  
Saraswati Genius School  
Jaipur

Saraswati Genius School  
Jaipur

Signature with stamp of the seal of the  
School/Institution

Fire Safety  
Certificate  
Attached

## PART-II

### Building Safety Report

Name of the School

Saraswati Genius School, Jaipur

Shri Parambhat Singh Junior Engineer on dated 2/5/25  
visited the above mentioned school building and on visually inspection, It seems  
visually safe subject to the following observation & conditions:-

- Parameters to check the stability and safety of building such as Architectural Drawings, Reports of Material used, Quality, Control Reports and certificate from the Engineer in Charge for construction are not available.
- In case any addition, alteration or expansion and modification to this building are done, certificate may be re-obtained after the completion from the undersigned.
- In case the building is affected by flood or if there is any settlement of walls/foundations or sagging of roofs etc, immediate inspection of the undersigned be arranged to check stability and safety of the building.
- A separate certificate regarding Fire Fighting should be obtained from the competent Authority.
- A separate certificate regarding Electrical works should be obtained from the competent Authority.
- The owner of the building/Management is fully responsible regarding safety of the building from all angles in spite of this report.
- The covered area of the building is 41448/- Sq. Ft.
- This report is not valid for legal purpose.

i) The building visually seems safe to occupy for normal use date up to 31/3/26 or up to  
Fire safety Certificate dt 17-08-2025 if not renewed by School


Sub Divisional Engineer,

Constn. Sub Divn., PWD B&R Branch,  
Jaipur.

To

Saraswati Genius School  
Jaitu

No. DB/3299



Dated: 14/07/2025

**Subject: for the issuance of the building safety certificate for the year 2025-26 (Saraswati Genius School, Jaitu)**

The above subject has been obtained in this office for getting the Building safety certificate of the school building for the year 2025-26. The building of your school was visually inspected by the office of the Sub Divisional Engineer and as per their report/recommendation, the school building safety certificate for the year 2025-26 is issued till 31-03-2026 or till the expiry date of fire safety certificate i.e. 17.08.2025 (whichever date comes first) subject to the following inspection and conditions:-

- 1) The school should have a plan to deal with any untoward incident, including a plan for safely evacuating children from the building during an emergency and coordinating with the relevant department. The school should regularly review and update this plan to ensure its effectiveness.
- 2) If any addition, change, expansion and modification is required or is to be made by the school in this building, then this office should arrange for an immediate inspection and after completing that part, its safety certificate should be obtained again from this office.
- 3) If the walls, foundation and roof of the building collapse due to a natural disaster or any other reason, then the school should immediately inform this office about the condition of the building and the building should be put into use only after an inspection.
- 4) Fire Safety and Electrical Safety Certificate should be obtained separately from the concerned department.
- 5) Keeping the safety of the school building in mind, it is the responsibility of the school management to get the building repaired. Despite this report, the school management is responsible for the safety of the building from all aspects.
- 6) Construction Architects (Innovus Structural Engineers and Consultants) on 11.07.2025 have been issued a structural safety certificate and as per their certificate the school is safe for use for the session 2025-26, but this school has not been constructed by this department, hence the structural safety of the school especially from the earthquake point of view cannot be ensured by this department.
- 7) The school must provide appropriate safety training to staff members, including procedures for handling emergencies, first aid and evacuation protocols.
- 8) Ten thousand rupees (10,000/-) received as building inspection fee as per the covered area of the school vide G.R. No. 17248554 dated 28.04.2025. The fire safety certificate of the school is valid till 17.08.2025 and the school management will be responsible for getting the fire certificate renewed within the time limit. If the fire safety certificate is not renewed by the school management, then the validity of this safety certificate will be till 17.08.2025.
- 9) This letter/certificate has no connection with the ownership of the school premises.
- 10) This letter/certificate has no relation to the plot area of the school.
- 11) This approval has no connection with the Scheduled Roads Act.
- 12) This report is not valid for legal purposes.

Attached Certificate

Attested the translation  
From Punjabi to English

**ATTESTED**

Sanjiv Kumar Mangla  
Advocate/Notary  
JAITU 15.7.2025

SD/-  
Executive Engineer,  
Provincial Division,  
PWD, B&R Branch,  
Faridkot -151203

Dated

ENDST. No.

A Copy of the above is sent to the Sub Divisional Engineer, Construction Sub Division, B&R Branch, Jaitu with reference to his letter no.38 dated 22.04.2025 for the information.

SD/-  
Executive Engineer,  
Provincial Division,  
PWD, B&R Branch,  
Faridkot -151203